

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Influent Flow and Loading

1. Monthly Average Flows and BOD Loadings

1.1 Verify the following monthly flows and BOD loadings to your facility.

Influent No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average BOD Concentration mg/L	x	8.34	=	Influent Monthly Average BOD Loading, lbs/day
January	15.8097	x	148	x	8.34	=	19,552
February	16.3964	x	152	x	8.34	=	20,761
March	27.6742	x	86	x	8.34	=	19,886
April	17.8167	x	124	x	8.34	=	18,366
May	15.1161	x	142	x	8.34	=	17,885
June	13.2567	x	154	x	8.34	=	17,012
July	13.0161	x	162	x	8.34	=	17,554
August	14.0290	x	142	x	8.34	=	16,671
September	11.5533	x	172	x	8.34	=	16,544
October	15.0194	x	147	x	8.34	=	18,353
November	13.0900	x	158	x	8.34	=	17,220
December	14.4419	x	151	x	8.34	=	18,168

2. Maximum Monthly Design Flow and Design BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	48	x	90	=	43.2
		x	100	=	48
Design BOD, lbs/day	31591	x	90	=	28431.9
		x	100	=	31591

2.2 Verify the number of times the flow and BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times BOD was greater than 90% of design	Number of times BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	0	0
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		0	0	0	0
Points		0	0	0	0
Total Number of Points					0

0

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?
 Yes Enter last calibration date (MM/DD/YYYY)

No

If No, please explain:

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

Yes

No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

Yes

No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks

Holding Tanks

Grease Traps

Yes

Yes

Yes

No

No

No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

Yes

gallons

No

Holding Tanks

Yes

gallons

No

Grease Traps

Yes

gallons

No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

Yes

No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Yes

No

If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.

Landfill leachate is accepted from a local landfill as a permitted discharge although it is not hauled.

Hauled waste is pH checked prior to discharge to be certain it is in compliance.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	10	1	0	0
February	30	27	11	1	0	0
March	30	27	10	1	0	0
April	30	27	16	1	0	0
May	30	27	11	1	0	0
June	30	27	12	1	0	0
July	30	27	9	1	0	0
August	30	27	13	1	0	0
September	30	27	10	1	0	0
October	30	27	10	1	0	0
November	30	27	9	1	0	0
December	30	27	5	1	0	0

* Equals limit if limit is <= 10

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		0	0
Points		0	0
Total number of points			0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

- Yes

Enter last calibration date (MM/DD/YYYY)

2021-07-21

- No

If No, please explain:

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

There were no problems that threatened treatment.

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

- Yes

- No

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

If Yes, please explain:

On September 8, 2021 the treatment plant had a final effluent mercury result of 7.7 ng/l which was attributed to rising sludge in 2 final clarifiers. Immediate changes were made to eliminate the rising sludge. A second sample was analyzed on September 30, 2021 which has a result of 1.2 ng/l which was well within the limit of 4.0 ng/l.

4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?

- Yes
- No

If Yes, please explain:

4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?

- Yes
- No
- N/A

Please explain unless not applicable:

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	6	1	0	0
February	30	27	5	1	0	0
March	30	27	4	1	0	0
April	30	27	9	1	0	0
May	30	27	9	1	0	0
June	30	27	6	1	0	0
July	30	27	5	1	0	0
August	30	27	8	1	0	0
September	30	27	11	1	0	0
October	30	27	6	1	0	0
November	30	27	5	1	0	0
December	30	27	4	1	0	0

* Equals limit if limit is <= 10

Months of Discharge/yr	12		
Points per each exceedance with 12 months of discharge:	7	3	
Exceedances	0	0	
Points	0	0	
Total Number of Points		0	

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Effluent Quality and Plant Performance (Ammonia - NH3)

1. Effluent Ammonia Results

1.1 Verify the following monthly and weekly average effluent values, exceedances and points for ammonia

Outfall No. 001	Monthly Average NH3 Limit (mg/L)	Weekly Average NH3 Limit (mg/L)	Effluent Monthly Average NH3 (mg/L)	Monthly Permit Limit Exceedance	Effluent Weekly Average for Week 1	Effluent Weekly Average for Week 2	Effluent Weekly Average for Week 3	Effluent Weekly Average for Week 4	Weekly Permit Limit Exceedance
January	25		1.446	0					
February	25		3.499	0					
March	25		2.752	0					
April	25		3.78	0					
May									
June									
July									
August									
September									
October									
November	25		3.537	0					
December	25		1.153	0					
Points per each exceedance of Monthly average:									10
Exceedances, Monthly:									0
Points:									0
Points per each exceedance of weekly average (when there is no monthly average):									2.5
Exceedances, Weekly:									0
Points:									0
Total Number of Points									0

0

NOTE: Limit exceedances are considered for monthly OR weekly averages but not both. When a monthly average limit exists it will be used to determine exceedances and generate points. This will be true even if a weekly limit also exists. When a weekly average limit exists and a monthly limit does not exist, the weekly limit will be used to determine exceedances and generate points.

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results

1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	.86	0.762	1	0
February	.86	0.725	1	0
March	.86	0.635	1	0
April	.86	0.735	1	0
May	.86	0.767	1	0
June	.86	0.709	1	0
July	.86	0.717	1	0
August	.86	0.749	1	0
September	.86	0.820	1	0
October	.86	0.680	1	0
November	.86	0.709	1	0
December	.86	0.736	1	0
Months of Discharge/yr			12	
Points per each exceedance with 12 months of discharge:				10
Exceedances				0
Total Number of Points				0

0

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Biosolids Quality and Management

1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

- Land applied under your permit
- Publicly Distributed Exceptional Quality Biosolids
- Hauled to another permitted facility
- Landfilled
- Incinerated
- Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

2. Land Application Site

2.1 Last Year's Approved and Active Land Application Sites

2.1.1 How many acres did you have?

9324.80 acres

2.1.2 How many acres did you use?

499.2 acres

2.2 If you did not have enough acres for your land application needs, what action was taken?

2.3 Did you overapply nitrogen on any of your approved land application sites you used last year?

Yes (30 points)

No

2.4 Have all the sites you used last year for land application been soil tested in the previous 4 years?

Yes

No (10 points)

N/A

3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

Outfall No. 002 - ANAEROBIC CAKE SLUDGE

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75	<15		<14.4		<14.6		<7		<7		<7.4			0	0
Cadmium		39	85	<3		<2.88		<2.91		1.7		1.6		1.3			0	0
Copper		1500	4300	550		507		532		601		636		577			0	0
Lead		300	840	31		25.3		31		33.5		49.3		42.3			0	0
Mercury		17	57	<.51		.33		.28		.84		<.37		<.34			0	0
Molybdenum	60		75	19		17.4		16.9		23.1		27.2		26.1		0		0
Nickel	336		420	28		26.4		27.4		29.4		37.4		29.7		0		0
Selenium	80		100	<15		<14.4		<14.6		8.6		6.7		<6.6		0		0
Zinc		2800	7500	830		732		736		835		950		738			0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

Exceedence Points

0 (0 Points)

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

- 1-2 (10 Points)
 - > 2 (15 Points)
- 3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)
- Yes
 - No (10 points)
 - N/A - Did not exceed limits or no HQ limit applies (0 points)
 - N/A - Did not land apply biosolids until limit was met (0 points)
- 3.1.3 Number of times any of the metals exceeded the ceiling limits = 0
- Exceedence Points
- 0 (0 Points)
 - 1 (10 Points)
 - > 1 (15 Points)
- 3.1.4 Were biosolids land applied which exceeded the ceiling limit?
- Yes (20 Points)
 - No (0 Points)
- 3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken? Has the source of the metals been identified?

0

4. Pathogen Control (per outfall):

4.1 Verify the following information. If any information is incorrect, use the Report Issue button under the Options header in the left-side menu.

Outfall Number:	002
Biosolids Class:	B
Bacteria Type and Limit:	Fecal Coliform
Sample Dates:	01/01/2021 - 02/28/2021
Density:	196,600
Sample Concentration Amount:	CFU/G TS
Requirement Met:	Yes
Land Applied:	No
Process:	Anaerobic Digestion
Process Description:	Anaerobic digestion: 30 - 45 day MCRT at 95 degrees F; 3/day temperature reading Requirement met.

Outfall Number:	002
Biosolids Class:	B
Bacteria Type and Limit:	Fecal Coliform
Sample Dates:	03/01/2021 - 04/30/2021
Density:	153,600
Sample Concentration Amount:	CFU/G TS
Requirement Met:	Yes
Land Applied:	Yes
Process:	Anaerobic Digestion
Process Description:	Anaerobic digestion: 30 - 45 day MCRT at 95 degrees F; 3/day temperature reading Requirement met

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Outfall Number:	002
Biosolids Class:	B
Bacteria Type and Limit:	Fecal Coliform
Sample Dates:	05/01/2021 - 06/30/2021
Density:	169,300
Sample Concentration Amount:	CFU/G TS
Requirement Met:	Yes
Land Applied:	Yes
Process:	Anaerobic Digestion
Process Description:	Anaerobic digestion: 30 - 45 day MCRT at 95 degrees F; 3/day temperature reading Requirement met.

Outfall Number:	002
Biosolids Class:	B
Bacteria Type and Limit:	Fecal Coliform
Sample Dates:	07/01/2021 - 08/31/2021
Density:	77,870
Sample Concentration Amount:	CFU/G TS
Requirement Met:	Yes
Land Applied:	Yes
Process:	Anaerobic Digestion
Process Description:	Anaerobic digestion: 30 - 45 day MCRT at 95 degrees F; 3/day temperature reading Requirement met.

Outfall Number:	002
Biosolids Class:	B
Bacteria Type and Limit:	Fecal Coliform
Sample Dates:	09/01/2021 - 10/31/2021
Density:	74,360
Sample Concentration Amount:	CFU/G TS
Requirement Met:	Yes
Land Applied:	Yes
Process:	Anaerobic Digestion
Process Description:	Anaerobic digestion: 30 - 45 day MCRT at 95 degrees F; 3/day temperature reading Requirement met.

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Outfall Number:	002
Biosolids Class:	B
Bacteria Type and Limit:	Fecal Coliform
Sample Dates:	11/01/2021 - 12/31/2021
Density:	142,500
Sample Concentration Amount:	CFU/G TS
Requirement Met:	Yes
Land Applied:	Yes
Process:	Anaerobic Digestion
Process Description:	Anaerobic digestion: 30 - 45 day MCRT at 95 degrees F; 3/day temperature reading Requirement met.

0

4.2 If exceeded Class B limit or did not meet the process criteria at the time of land application.

4.2.1 Was the limit exceeded or the process criteria not met at the time of land application?

Yes (40 Points)

No

If yes, what action was taken?

5. Vector Attraction Reduction (per outfall):

5.1 Verify the following information. If any of the information is incorrect, use the Report Issue button under the Options header in the left-side menu.

Outfall Number:	002
Method Date:	02/28/2021
Option Used To Satisfy Requirement:	Incorporation when land apply
Requirement Met:	Yes
Land Applied:	No
Limit (if applicable):	
Results (if applicable):	

Outfall Number:	002
Method Date:	04/30/2021
Option Used To Satisfy Requirement:	Incorporation when land apply
Requirement Met:	Yes
Land Applied:	Yes
Limit (if applicable):	
Results (if applicable):	

Outfall Number:	002
Method Date:	06/30/2021
Option Used To Satisfy Requirement:	Incorporation when land apply
Requirement Met:	Yes
Land Applied:	Yes
Limit (if applicable):	
Results (if applicable):	

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Outfall Number:	002		
Method Date:	08/31/2021		
Option Used To Satisfy Requirement:	Incorporation when land apply		
Requirement Met:	Yes		
Land Applied:	Yes		
Limit (if applicable):			
Results (if applicable):			
Outfall Number:	002	0	
Method Date:	10/31/2021		
Option Used To Satisfy Requirement:	Incorporation when land apply		
Requirement Met:	Yes		
Land Applied:	Yes		
Limit (if applicable):			
Results (if applicable):			
Outfall Number:	002		
Method Date:	12/31/2021		
Option Used To Satisfy Requirement:	Incorporation when land apply		
Requirement Met:	Yes		
Land Applied:	Yes		
Limit (if applicable):			
Results (if applicable):			
<p>5.2 Was the limit exceeded or the process criteria not met at the time of land application?</p> <p><input type="radio"/> Yes (40 Points)</p> <p><input checked="" type="radio"/> No</p> <p>If yes, what action was taken?</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>			
<p>6. Biosolids Storage</p> <p>6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site?</p> <p><input checked="" type="radio"/> >= 180 days (0 Points)</p> <p><input type="radio"/> 150 - 179 days (10 Points)</p> <p><input type="radio"/> 120 - 149 days (20 Points)</p> <p><input type="radio"/> 90 - 119 days (30 Points)</p> <p><input type="radio"/> < 90 days (40 Points)</p> <p><input type="radio"/> N/A (0 Points)</p> <p>6.2 If you checked N/A above, explain why.</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>			0
<p>7. Issues</p> <p>7.1 Describe any outstanding biosolids issues with treatment, use or overall management:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>			

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Staffing and Preventative Maintenance (All Treatment Plants)

<p>1. Plant Staffing</p> <p>1.1 Was your wastewater treatment plant adequately staffed last year?</p> <ul style="list-style-type: none">● Yes○ No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>Could use more help/staff for:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?</p> <ul style="list-style-type: none">● Yes○ No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
<p>2. Preventative Maintenance</p> <p>2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?</p> <ul style="list-style-type: none">● Yes (Continue with question 2) <input type="checkbox"/><input type="checkbox"/>○ No (40 points) <input type="checkbox"/><input type="checkbox"/> <p>If No, please explain, then go to question 3:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?</p> <ul style="list-style-type: none">● Yes○ No (10 points) <p>2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?</p> <ul style="list-style-type: none">● Yes<ul style="list-style-type: none">○ Paper file system○ Computer system● Both paper and computer system○ No (10 points)	0
<p>3. O&M Manual</p> <p>3.1 Does your plant have a detailed O&M and Manufacturer Equipment Manuals that can be used as a reference when needed?</p> <ul style="list-style-type: none">● Yes○ No	
<p>4. Overall Maintenance /Repairs</p> <p>4.1 Rate the overall maintenance of your wastewater plant.</p> <ul style="list-style-type: none">● Excellent○ Very good○ Good○ Fair○ Poor <p>Describe your rating:</p>	

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

We have a qualified maintenance staff, supervised by a Master Electrician. Staff is cross-trained and does an excellent job.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Operator Certification and Education

1. Operator-In-Charge

1.1 Did you have a designated operator-in-charge during the report year?

- Yes (0 points)
- No (20 points)

Name:

MARY FRANCES T KLIMEK

Certification No:

23898

0

2. Certification Requirements

2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?

Sub Class	SubClass Description	WWTP		OIC	
		Advanced	OIT	Basic	Advanced
A1	Suspended Growth Processes	X			X
A2	Attached Growth Processes				
A3	Recirculating Media Filters				
A4	Ponds, Lagoons and Natural				
A5	Anaerobic Treatment Of Liquid				
B	Solids Separation	X			X
C	Biological Solids/Sludges	X			X
P	Total Phosphorus	X			X
N	Total Nitrogen				
D	Disinfection	X			X
L	Laboratory	X			X
U	Unique Treatment Systems		X		
SS	Sanitary Sewage Collection	X	NA	X	NA

0

2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS is required 5 years after permit reissuance.)

- Yes (0 points)
- No (20 points)

3. Succession Planning

3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?

- One or more additional certified operators on staff
- An arrangement with another certified operator
- An arrangement with another community with a certified operator
- An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year
- A consultant to serve as your certified operator
- None of the above (20 points)

If "None of the above" is selected, please explain:

0

4. Continuing Education Credits

4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates?

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

OIT and Basic Certification: ○ Averaging 6 or more CECs per year. ○ Averaging less than 6 CECs per year. Advanced Certification: ● Averaging 8 or more CECs per year. ○ Averaging less than 8 CECs per year.	
---	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Financial Management

1. Provider of Financial Information Name: <input type="text" value="Kenneth Scolaro"/> Telephone: <input type="text" value="262-636-9433"/> (XXX) XXX-XXXX E-Mail Address (optional): <input type="text" value="ken.scolaro@cityofracine.org"/>		
2. Treatment Works Operating Revenues 2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ? ● Yes (0 points) <input type="checkbox"/> <input type="checkbox"/> ○ No (40 points) If No, please explain: <input type="text"/> 2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised? Year: <input type="text" value="2021"/> ● 0-2 years ago (0 points) <input type="checkbox"/> <input type="checkbox"/> ○ 3 or more years ago (20 points) <input type="checkbox"/> <input type="checkbox"/> ○ N/A (private facility) 2.3 Did you have a special account (e.g., CFWP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system? ● Yes (0 points) ○ No (40 points)		0
REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]		
3. Equipment Replacement Funds 3.1 When was the Equipment Replacement Fund last reviewed and/or revised? Year: <input type="text" value="2021"/> ● 1-2 years ago (0 points) <input type="checkbox"/> <input type="checkbox"/> ○ 3 or more years ago (20 points) <input type="checkbox"/> <input type="checkbox"/> ○ N/A If N/A, please explain: <input type="text"/>		
3.2 Equipment Replacement Fund Activity		
3.2.1 Ending Balance Reported on Last Year's CMAR	\$ <input type="text" value="3,214,426.04"/>	
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	\$ <input type="text" value="0.00"/>	
3.2.3 Adjusted January 1st Beginning Balance	\$ <input type="text" value="3,214,426.04"/>	
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	\$ <input type="text" value="1,866.00"/>	
	+	

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*) -

\$ 0.00

3.2.6 Ending Balance as of December 31st for CMAR Reporting Year

\$ 3,216,292.04

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

3.3 What amount should be in your Replacement Fund?

\$ 1,739,565.00

0

Please note: If you had a CFWP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

- Yes
- No

If No, please explain.

4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

- Yes - If Yes, please provide major project information, if not already listed below.
- No

Project #	Project Description	Estimated Cost	Approximate Construction Year
1	UV System Replacement	14,000,000	2023
2	Plant Engines, Blowers and Engine Generator	11,000,000	2023
3	Chicory Road Interceptor and Tank	18,000,000	2023
4	Goold and Main Storage Improvement	52,000,000	2024

5. Financial Management General Comments

ENERGY EFFICIENCY AND USE

6. Collection System

6.1 Energy Usage

6.1.1 Enter the monthly energy usage from the different energy sources:

COLLECTION SYSTEM PUMPAGE: Total Power Consumed

Number of Municipally Owned Pump/Lift Stations:

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	121,015	3,010
February	95,778	4,033
March	137,197	2,042
April	116,641	1,831
May	87,048	1,772
June	93,735	171
July	87,420	97
August	79,700	87
September	87,002	382
October	78,557	1,424
November	96,803	3,693
December	90,036	4,920
Total	1,170,932	23,462
Average	97,578	1,955

6.1.2 Comments:

6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- Comminution or Screening
- Extended Shaft Pumps
- Flow Metering and Recording
- Pneumatic Pumping
- SCADA System
- Self-Priming Pumps
- Submersible Pumps
- Variable Speed Drives
- Other:

6.2.2 Comments:

6.3 Has an Energy Study been performed for your pump/lift stations?

No

Yes

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

As equipment is replaced, energy use is considered in the decision making process.

7. Treatment Facility

7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	631,089	490.10	1,288	606.11	1,041	52,281
February	492,511	459.10	1,073	581.31	847	54,694
March	565,317	857.90	659	616.47	917	34,477
April	518,978	534.50	971	550.98	942	24,339
May	489,686	468.60	1,045	554.44	883	22,650
June	569,949	397.70	1,433	510.36	1,117	9,350
July	598,919	403.50	1,484	544.17	1,101	9,613
August	521,121	434.90	1,198	516.80	1,008	12,873
September	593,667	346.60	1,713	496.32	1,196	15,102
October	490,490	465.60	1,053	568.94	862	18,643
November	533,532	392.70	1,359	516.60	1,033	32,285
December	657,102	447.70	1,468	563.21	1,167	43,526
Total	6,662,361	5,698.90		6,625.71		329,833
Average	555,197	474.91	1,229	552.14	1,010	27,486

7.1.2 Comments:

7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- Aerobic Digestion
- Anaerobic Digestion
- Biological Phosphorus Removal
- Coarse Bubble Diffusers
- Dissolved O2 Monitoring and Aeration Control
- Effluent Pumping
- Fine Bubble Diffusers
- Influent Pumping
- Mechanical Sludge Processing
- Nitrification
- SCADA System
- UV Disinfection
- Variable Speed Drives
- Other:

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 2021

7.2.2 Comments:

Effluent pumping is for reuse in the plant.

7.3 Future Energy Related Equipment

7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?

As part of the replacement of deficient equipment identified in the Facility Plan, energy efficiency is taken into consideration when choosing replacements.

8. Biogas Generation

8.1 Do you generate/produce biogas at your facility?

- No
- Yes

If Yes, how is the biogas used (Check all that apply):

- Flared Off
- Building Heat
- Process Heat
- Generate Electricity
- Other:

Gas engines

9. Energy Efficiency Study

9.1 Has an Energy Study been performed for your treatment facility?

- No
- Yes

Entire facility

Year:

By Whom:

Describe and Comment:

Part of the facility

Year:

2020

By Whom:

Black & Veatch, ITT Sanitaire, Brown & Caldwell

Describe and Comment:

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Several studies have covered parts of the treatment system. 2020 is listed above as the start of the most recent plan.
2011 ITT Sanitaire
March 2011 Black & Veatch Co-Generation and Co-Digestion Evaluation
October 2012 Brown & Caldwell Evaluation of Existing Engine/Blower Study.
2020 - Present Energy usage was reviewed throughout the Facility Plan for those systems that are part of the project - UV, biogas, engines and blowers, aeration, etc.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 2021

Sanitary Sewer Collection Systems

1. Capacity, Management, Operation, and Maintenance (CMOM) Program

1.1 Do you have a CMOM program that is being implemented?

- Yes
- No

If No, explain:

1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

- Yes
- No (30 points)
- N/A

If No or N/A, explain:

1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

- Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

Clean the annual 1/3 of the collection system and catch-up from 2020 due to COVID-19 related shutdowns. Begin discussion on the Chicory Road Storage Basin and the North Wisconsin Avenue Storage Pipe.

Did you accomplish them?

- Yes
- No

If No, explain:

- Organization [NR 210.23 (4) (b)]

Does this chapter of your CMOM include:

- Organizational structure and positions (eg. organizational chart and position descriptions)
- Internal and external lines of communication responsibilities
- Person(s) responsible for reporting overflow events to the department and the public

- Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

Racine City Code of Ordinances Chapter 98

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY) 2022-03-15

Does your sewer use ordinance or other legally binding document address the following:

- Private property inflow and infiltration
- New sewer and building sewer design, construction, installation, testing and inspection
- Rehabilitated sewer and lift station installation, testing and inspection
- Sewage flows satellite system and large private users are monitored and controlled, as necessary
- Fat, oil and grease control
- Enforcement procedures for sewer use non-compliance

- Operation and Maintenance [NR 210.23 (4) (d)]

Does your operation and maintenance program and equipment include the following:

- Equipment and replacement part inventories
- Up-to-date sewer system map

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

- A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation
- A description of routine operation and maintenance activities (see question 2 below)
- Capacity assessment program
- Basement back assessment and correction
- Regular O&M training

Design and Performance Provisions [NR 210.23 (4) (e)]

What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?

- State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements
- Construction, Inspection, and Testing
- Others:

Overflow Emergency Response Plan [NR 210.23 (4) (f)]

Does your emergency response capability include:

- Responsible personnel communication procedures
- Response order, timing and clean-up
- Public notification protocols
- Training
- Emergency operation protocols and implementation procedures

Annual Self-Auditing of your CMOM Program [NR 210.23 (5)]

Special Studies Last Year (check only those that apply):

- Infiltration/Inflow (I/I) Analysis
- Sewer System Evaluation Survey (SSES)
- Sewer Evaluation and Capacity Management Plan (SECAP)
- Lift Station Evaluation Report
- Others:

0

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	51.84	% of system/year
Root removal	7.05	% of system/year
Flow monitoring	36.35	% of system/year
Smoke testing	0	% of system/year
Sewer line televising	0.73	% of system/year
Manhole inspections	25.97	% of system/year
Lift station O&M	100.6	# per L.S./year
Manhole rehabilitation	0.33	% of manholes rehabbed
Mainline rehabilitation	0.10	% of sewer lines rehabbed
Private sewer inspections	0.09	% of system/year

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Private sewer I/I removal % of private services

River or water crossings % of pipe crossings evaluated or maintained

Please include additional comments about your sanitary sewer collection system below:

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

<input type="text" value="24.05"/>	Total actual amount of precipitation last year in inches
<input type="text" value="35"/>	Annual average precipitation (for your location)
<input type="text" value="254.7"/>	Miles of sanitary sewer
<input type="text" value="14"/>	Number of lift stations
<input type="text" value="0"/>	Number of lift station failures
<input type="text" value="0"/>	Number of sewer pipe failures
<input type="text" value="4"/>	Number of basement backup occurrences
<input type="text" value="4"/>	Number of complaints
<input type="text" value="15.19"/>	Average daily flow in MGD (if available)
<input type="text" value="28.48"/>	Peak monthly flow in MGD (if available)
<input type="text" value="51.9"/>	Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

<input type="text" value="0.00"/>	Lift station failures (failures/year)
<input type="text" value="0.00"/>	Sewer pipe failures (pipe failures/sewer mile/yr)
<input type="text" value="0.00"/>	Sanitary sewer overflows (number/sewer mile/yr)
<input type="text" value="0.02"/>	Basement backups (number/sewer mile)
<input type="text" value="0.02"/>	Complaints (number/sewer mile)
<input type="text" value="1.9"/>	Peaking factor ratio (Peak Monthly:Annual Daily Avg)
<input type="text" value="3.4"/>	Peaking factor ratio (Peak Hourly:Annual Daily Avg)

4. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OVERFLOWS REPORTED **

Date	Location	Cause	Estimated Volume
None reported			

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

- Yes
- No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

- Yes

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

<ul style="list-style-type: none">● No <p>If Yes, please describe:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>
<p>5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:</p> <div style="border: 1px solid black; padding: 5px;">2021 was a very dry year. There were no overflows within the system and there were no rain events that necessitated the use of storage tanks.</div>
<p>5.4 What is being done to address infiltration/inflow in your collection system?</p> <div style="border: 1px solid black; padding: 5px;">Even though 2021 was a dry year, the utility continues to evaluate and correct deficiencies within the collection system. The utility has been working with the communities that contribute flow to the system to evaluate the need for additional storage. CCTV is used to pinpoint areas that may need lining or relaying of pipe.</div>

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Grading Summary

WPDES No: 0025194

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Ammonia	A	4	5	20
Phosphorus	A	4	3	12
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			37	148
GRADE POINT AVERAGE (GPA) = 4.00				

Notes:

- A = Voluntary Range (Response Optional)
- B = Voluntary Range (Response Optional)
- C = Recommendation Range (Response Required)
- D = Action Range (Response Required)
- F = Action Range (Response Required)

Compliance Maintenance Annual Report

Racine Wastewater Utility

Last Updated: Reporting For:
6/1/2022 **2021**

Resolution or Owner's Statement

Name of Governing
Body or Owner:

Date of Resolution or
Action Taken:

Resolution Number:

Date of Submittal:

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F):

Influent Flow and Loadings: Grade = A

Effluent Quality: BOD: Grade = A

Effluent Quality: TSS: Grade = A

Effluent Quality: Ammonia: Grade = A

Effluent Quality: Phosphorus: Grade = A

Biosolids Quality and Management: Grade = A

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = A

Collection Systems: Grade = A

(Regardless of grade, response required for Collection Systems if SSOs were reported)

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS

(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

G.P.A. = 4.00