



City of Racine

City Hall
730 Washington Ave.
Racine, WI 53403
www.cityofracine.org

Legislation Text

File #: 0255-23, **Version:** A

Subject: Request by the Village of Mount Pleasant for the Approval of a Sanitary Sewer Extension for the Leo Living Development

The Wastewater Utility Director presented the sewer extension request for the Leo Living Development within the Village of Mount Pleasant. Per Sewer Agreement Section 3.3a, the Commission is required to approve all SSR party sewer extensions. The Mount Pleasant Sewer Utility District has reviewed and approved project plans, and sufficient capacity is available. The extension entails approximately 3,800 L.F. of 8" diameter sanitary sewer.

Recommendation: To Approve

Fiscal Note: N/A